



June 30, 2016

To: All Planholders for the Non-Potable Water Distribution System – Phase III Project

Re: **Clarification No. 2 to Questions**

This document contains clarifications to questions asked by potential bidders. Any additional questions need to be submitted to the City at [engineering@brentwoodca.gov](mailto:engineering@brentwoodca.gov).

**1. Is the Contractor responsible to re-establish landscaping along the fence in Miwok Park?**

Addendum No. 2, being issued tomorrow, will address this question.

**2. Have the soils in the railroad right-of-way been tested for contamination?**

No, soils have not been tested for contamination. If soil contamination is identified during construction the Contractor shall immediately notify the Engineer.

**3. What is the thickness of AC in Grant Street?**

Based on as-built information the roadway structural section is 4 inches of AC over 15 inches AB. Grant Street as-built plans are available on the City website located at: [http://www.brentwoodca.gov/gov/pw/cip/pw\\_projects\\_out\\_to\\_bid.asp](http://www.brentwoodca.gov/gov/pw/cip/pw_projects_out_to_bid.asp)

**4. Has Grant Street been paved within the last 3 years, invoking Note 9B and Note 9C of Sheet ST-25b?**

Yes, Grant Street was slurry sealed within the last 3 years, however Note 9B and 9C of Sheet ST-25b will not apply for this project. The City is planning on slurry sealing the roadway following project completion.

**5. The “Casing Pipe” paragraph (sentence 8) of Subsection B “UPRR Crossing” of Section TS-22 states “the casing pipe shall be large enough to allow the carrier pipe to be removed...”, however the casing is grouted.**

Addendum No. 2, being issued tomorrow, will address this question.

Sincerely,

James Campero, P.E.  
Construction Manager

---

PUBLIC WORKS DEPARTMENT

Engineering Division  
150 City Park Way  
Phone (925) 516-5420  
Fax (925) 516-5421

Mailing Address  
150 City Park Way, Brentwood, CA 94513  
[www.brentwoodca.gov](http://www.brentwoodca.gov)

Operations Division  
2201 Elkins Way  
Phone (925) 516-6000  
Fax (925) 516-6001