



---

March 21, 2025

**ADDENDUM NO. 1**

**Water Line Improvement – Kent Drive Project  
CIP Project No. 562-56421**

**NOTICE TO PROPOSERS:**

The following clarifications, amendments, additions and/or deletions as set forth herein shall apply to the above documents and shall be made a part thereof and shall be subject to all the requirements thereof as though originally specified and/or shown. Submitters shall assure themselves that all addendum changes have been incorporated into their proposal.

**A. CLARIFICATIONS**

1. Is there a pre-bid job walk? If so is that mandatory?

*There is no pre-bid job walk for this Project.*

2. If possible, please reply back to this email with the engineer's estimate or kindly forward this to the person best able to provide this information.

*The Engineer's Estimate for this Project is approximately \$317,000.*

3. Now that I have received bid documents, am I on the bidders list and eligible to bid this project?

*The City of Brentwood does not require bidders to be on the plan holder's list to be eligible to bid; the intent of the plan holder's list is so bidders can be made aware of Project updates such as, addenda.*

4. Will the city be conducting the bacterial sample test for the Kent dr project or will we need to find a third-party test service? If so, does the city have a preferred company to work with?

*Please refer to Section 33 13 00 – Pressure Pipeline Testing and Disinfection of the Technical Specifications. The Contractor will be responsible for getting a certified tester to perform the testing.*

5. For hydrostatic testing is the city, allowing the contractor to perform the hydrostatic test?

*Please refer to Technical Specifications Section 33 13 00 – Pressure Pipeline Testing and Disinfection. The Contractor will be responsible for getting a certified tester to perform the testing.*

6. As far as testing for the trench, will we need to find a third-party company to perform the compaction test or does the city perform such test?

*Please see updated Technical Specifications, Section 31 23 16 - Utility Earthwork, Subsection 1.5 – Quality Assurance, A. General below. The language requiring the Contractor to retain services, at their own expense, an independent materials testing laboratory to perform testing services has been stricken. The City will retain the third-party consultant for compaction testing in accordance with Section 7.8 of the General Conditions.*

7. When it comes to the backfill, to clarify, can we use Native soil for backfill in the trench zone? Or is all excavated native soil to be hauled off?

*Please refer Technical Specifications, Section 31 23 16 – Utility Earthwork, Subsection 2.1 regarding suitable backfill and native material.*


## **B. AMENDMENTS**

1. In the Technical Specifications, Section 31 23 16 Utility Earthwork, Part 1 – General, 1.5 – Quality Assurance, A. General, **delete** the following:

~~The Contractor, at his own expense, shall retain the services of an approved, independent materials testing laboratory to perform testing services. Compaction testing of bedding, fill and backfill materials will be performed by the Contractor to ensure compliance with the plans and specifications. The Contractor shall provide all material analyses (gradations, Proctor curves, etc.) necessary to evaluate the materials and perform field tests on all materials used. The Owner may obtain independent material analyses. If independent analyses are obtained by the Owner, the Owner will have the final authority as to which analyses are used for quality assurance testing. Areas where test results indicate noncompliance shall be corrected before placing additional materials.~~

All bidders shall acknowledge receipt and acceptance of Addendum No. 1 in the space provided on the Bid Proposal, page 9, of the Contract Documents.

**-END OF ADDENDUM NO. -1-**



Vatsal Patel, P.E.  
Engineering Manager