



---

September 2, 2025

**ADDENDUM NO. 2**

**Request for Proposals – Lone Tree Way- Union Pacific At-Grade Crossing Project  
CIP Project No. 336-31340**

**NOTICE TO PROPOSERS:**

The following clarifications, amendments, additions and/or deletions as set forth herein shall apply to the above documents, shall be made a part thereof, and shall be subject to all the requirements thereof as though originally specified and/or shown. Submitters shall assure themselves that all addendum changes have been incorporated into their proposal.

**A. CLARIFICATIONS**

1. Is it also possible to provide the minutes from the five diagnostic meetings that were held in the previous phase of the project?

*Yes, the meeting minutes can be requested by emailing Anju Pillai at [apillai@brentwoodca.gov](mailto:apillai@brentwoodca.gov).*

2. The RFP lists Utility Coordination as a task item and the Lone Tree Way At-Grade Widening Concept Plan shows the relocation of the overhead utility lines into a underground joint trench that is "By Other Future Project". Can the City please confirm if 1) the relocation of overhead utility lines has/would be coordinated through a separate project or if the consultant of this project would be expected to coordinate the relocation of these overhead utility lines, and 2) if the City wants the consultant of this project to perform the joint trench design/coordination?

*Yes, the consultant has to coordinate with the utility agencies and accomplish the relocation of the overhead utility lines to new poles relocated within the City's right-of-way, prior to the construction of the widening improvements. There shall be no undergrounding of any utility lines with this project.*

**-END OF ADDENDUM NO. -1-**

---

Anju Pillai, P.E.  
Engineering Manager